



Reversing Valve Diagnostics

HEATING CYCLE

SYSTEM OPERATION

RESULTS ARE HIGHER SUCTION PRESSURES WITH HIGH SUPERHEAT. HEAD PRESSURES WILL BE LOWER AND SUBCOOLING WILL BE LOW.

KEY AREA IS TP-3 AND TP-4

Cooling TP-1 _____°F TP-2 _____°F

- Minus

TP-4 _____°F TP-3 _____°F

_____°F = Differential = _____°F

DIFFERENTIAL: 7°F OR HIGHER, REPLACE THE REVERSING VALVE AND DRIER

HEATING CYCLE

